



(2004)量认(国)字(B0585)号

# National Test Center of Polymer & Building Materials



No.L1049

No.2004 (X)0563

**CUSTOMER:** Fangxing Building Materials Co., Ltd.

## SAMPLES FOR TESTING

**Name:** Reinforced PVC corrugated sheet coated with Geloy

**Manufacturer:** Fangxing Building Materials Co., Ltd.

**Appearance:** Red corrugated sheet

**DATE OF RECEIPT:** 2004-08-16

**TEST PERIOD:** 2004-08-16 to 2004-09-30

**THIS REPORT COMPRISES 2 PAGES.**

**DIRECTOR:** 李进

**DATE:** 2004.09.30



Address: No. 14, beisanhuandonglu, Chaoyang district, Beijing, China Post Code: 100013  
Tel: +86(0)1064208747, +86(0)1064200694, +86(0)1064216131-2479, 2484, 2436, 2465  
Fax: +86(0)1064208747, +86(0)1064216131-2485  
E-mail: [plastic-test@brici.ac.cn](mailto:plastic-test@brici.ac.cn) Web site: [www.plastic-test.net](http://www.plastic-test.net)



(2004)量认(国)字(B0585)号

# National Test Center of Polymer & Building Materials



No.L1049


## TESTING RESULTS

No. 2004 (X)0563

No.	Item	Unit	Result	Test Methods
1	Coefficient of linear expansion	1/°C	$4.93 \times 10^{-5}$	GB/T 1036-1989
2	Coefficient of thermal conductivity	W/(m.k)	0.325	GB/T 10297-1998

Note: Coefficient of thermal conductivity is subcontracted item.

(HEREINAFTER IS EMPTY)



Test: 孙泉 胡孝义

Check: 刘小春

Director: 李生德